



October 8, 2025

Environmental Planner
York Town Hall
Second Floor
186 York Street
York, ME 03909

To Whom It May Concern,

Thank you for the opportunity to bid on the York Village Fire Station roof mounted solar PV array project.

V.H. Energy proposes to install a 25.6 KW solar photo voltaic system at the York Village Fire Station in York, ME. A 64 ZnShine 400W panel system will be installed on the south facing roof of the building. Additionally, the system will also consist of a SolarEdge inverter(s), and each ZnShine module will be serviced by an individual power optimizer. The power from the solar inverter(s) will then be fed into the electric service panel. We estimate that this system would potentially offset approximately 32,000 kWh annually. If your current power consumption were to remain the same, a 25.6 KW system will offset around 100% of that usage. All required town permits, inspection scheduling and utility interconnection application and fees are included in the system price.

Please feel free to contact me with any questions on my mobile at (603) 731-3169 or by email at vhromis@vh-energy.com.

Best,

Vladimir Hromis
Owner, V.H. Energy


System size for 25.6 KW System W/ No Batteries

Average annual cost of electricity	\$ 7,680.00			
Average monthly bill	\$ 640.00			
Utility Rate per KW	0.24	REC Price		
Average annual KWh	32000.00	\$ 30.00		
Average monthly KWh usage	2666.67			
Orientation	195 Degrees, 8 pitch			
Solar Panel Model and Power	ZnShine 400W B/B			
Inverter Type	Solar Edge with Optimizers			
Hours of Sunlight in NH	4			
System Efficiency, multiplier	1.16	# Panels Needed		
Solar Panel Size in Watts	400	64		
Suggested System Size DC	25.78			
System Size in DC Kilowatts	25.600	AdditionalCost N/A		
Price per Watt DC (Solar Only)	2.7	\$ -		
System Price	System Cash Price			
State Rebate	\$ 69,120.00			
Commercial Depreciation	\$ -			
Federal Tax Credit 30% (if applicable)	\$ 20,736.00			
Net system cost after rebates	\$ 48,384.00			
	Payback period			
	Monthly Payment			
	before applied incentives			
	after applied incentives			
	before applied incentives			
	Interest Rate			
	Interest Paid			
Cash Price	\$ 69,120.00	6.3 years		
Upfront System Cost	(net cost/utility bill)			



YORKFIRESTATION

Firehouse Drive 1, York, Maine, 03909, United States | Oct 2, 2025



SYSTEM OVERVIEW

 64 PV modules 2 Inverters 64 Optimizers

FINANCIAL OVERVIEW

System Price

\$ 69,120

SIMULATION RESULTS

	Installed DC Power		Max Achieved AC Power		Annual Usable Solar Production		Annual CO ₂ Emission Saved		Annual Equivalent Trees Planted
	25.60 kW _p		20.00 kW		35.71 MWh		25.24 t		1,159


YORKFIRESTATION

Firehouse Drive 1, York, Maine, 03909, United States | Oct 2, 2025



ESTIMATED MONTHLY ENERGY

5 MWh



PV MODULES

#	Module	Model	Peak power	Racking type	Orientation	Azimuth	Tilt
64	ZNShine PV-tech Co. Ltd., ZXM7-SH108-400 Full Black		25.6 kWp			129°	35°
Total: 64			25.6 kWp				

BILL OF MATERIALS (BOM)

Items	Part Number	Quantity	Price (\$)	Total (\$)
Base Price per W (DC)		25600	2.70	69,120.00

YORKFIRESTATION

Firehouse Drive 1, York, Maine, 03909, United States | Oct 2, 2025



BILL OF MATERIALS (BOM) (CONTINUED)

Items	Part Number	Quantity	Price (\$)	Total (\$)
 SE10KUS (SE-SIN)		2		
 C651U		64		
 ZXM7-SH108-400 Full Black		64		
				Total Price \$ 69,120.00

ELECTRICAL DESIGN


Inverters & Storage	Strings per inverter	Optimizers per string	PV modules per string
 2 xSE10KUS (SE-SIN) 12.71kW 127% Oversizing	 1 x string	 32 x C651U	 32

YORKFIRESTATION

Firehouse Drive 1, York, Maine, 03909, United States | Oct 2, 2025



SYSTEM LOSS DIAGRAM



SIMULATION PARAMETERS



LOCATION & GRID

Time zone	EDT (New_York)
Weather station	Pease (AFB)/Portsmouth (14 km away)
Station altitude	31 m
Station data source	Meteonorm 8.2
Grid	208V L-L, 120V L-N



LOSS FACTORS

Near shading	Enabled
Albedo	0.20
Bi-Facial Albedo	0.30
Soiling/Snow	0%
Incidence angle modifier (IAM), ASHRAE b0 param.	0.05
Thermal loss factor Uc (const) Flush mount	20
Thermal loss factor Uc (const) Tilted	29
LID loss factor	0%
System unavailability	0%